

# TANK LEVEL & LEAKS DETECTION MONITORING - ALARM






RDM2020310

Weatherproof housing to IP66 for external mounting

3.8" Mono or 4.5" Color display customized design

Wall mounting bracket

Flashing beacon



**Multi Purpose:** The tank alarm can be used wherever a high, low or bund level alarm is required in either vertical or horizontal tanks.

**Alarm Condition:** Float activated switches detect alarm conditions, a maximum of 3 float switches can be installed, monitoring high, low or bund levels.

**Suits Most Fuels:** The tank alarm is suitable for many liquids including diesel, gasoil, oils, & water.

**Simple to Install:** Easy installation via a wall mounting bracket & fast wiring using our plug & socket field connections.

**Configuration:** Switches installed in the main unit allow easy float configuration.

**Housing:** Aluminum Die cast Powder coated IP66. Supporting the powerful sounder, beacon (mains versions), test & mute buttons & channel indicators.

**System Test:** Pushing the test button activates a full system test, checking all float switches installed & all other components, the sounder activates as notification of a successful test.

**Versions:** Tank alarm is available in either 230VAC / 24DC / 12DC.

**Options:** 2" Flanged or 1-1/2 and 2" threaded



Field Assembled Kit

**RAJKOT DIESEL MACHINES TR. EST.**  
P.O. Box: 30741, Industrial area - 01, Sharjah, UAE.  
Tel: +971 65523589, Mob: +971504628276.  
Email: redimate@elm.ae, joya.gomez@rajkotmarine.com.  
Web: www.rajkotdiesel.com

**RAJKOT MARINE L.L.C.**  
P.O. Box: 5861, Jaraf area - 01, Ajman, UAE.  
Tel: +971 67487580, Mob: +971504628276.  
Email: redimate@elm.ae, joyantony@rajkotmarinelc.ae.  
Web: www.rajkotmarine.com

**4JB AUTOMATION & POWER CONTROLS PVT. LTD.**  
P.O. Box: 682028, Arakad Road, Kochi, Kerala, India.  
Tel: +91 4842808380, Mob: +91 9500903083.  
Email: redimate@elm.ae, sales@rajkotmarinelc.ae.  
Web: www.4jbautomation.com